



Probewell Lab Inc.
 4715 rue des Replats
 G2J 1B8, Quebec, Canada
 418-626-1126

Report Date: 2019-05-23 13:56
Test Date: 2019-05-10 14:35
Socket ID: 91003206
Model: Model

Meter Test Results

Meter ID: 00292822

Form: 16S **Line Voltage:** 236.62 Vrms **Test Mode:** Full Test
TA: 30.00 A **Line Frequency:** 60.01 Hz **Altitude:** N/A
KH: 36.0 **Weighting Factor:** 4 **Longitude:** N/A
Latitude: N/A

		Error	Amp	Energy	Optical Pickup
ABC	HL	99.93 %	30.00 A	144.09 Wh	4 pulses
	PF	99.94 %	30.00 A	72.04 Wh	2 pulses
	LL	99.98 %	3.00 A	36.01 Wh	1 pulses
	WT	99.95 %			
A	HL	99.92 %	30.00 A	72.05 Wh	2 pulses
	PF	99.93 %	30.00 A	36.02 Wh	1 pulses
	LL	-	-	-	-
	WT	99.93 %			
B	HL	99.93 %	30.00 A	72.05 Wh	2 pulses
	PF	99.95 %	30.00 A	36.02 Wh	1 pulses
	LL	-	-	-	-
	WT	99.94 %			
C	HL	99.91 %	30.00 A	72.07 Wh	2 pulses
	PF	99.91 %	30.00 A	36.03 Wh	1 pulses
	LL	-	-	-	-
	WT	99.91 %			