



Your Company Name Here
 Your company address here
 12345, HI, USA
 123-456-7890

Report Date: 2020-02-28 11:14
Test Date: 2020-02-28 16:11
Serial Number: 10036089
Socket Model: XT3

Primary/Secondary Report

Site C Info

Socket

Form: 9S
 Wiring: Wye
 Longitude: -71.33017
 Latitude: 46.80955
 Altitude: 1.90000

CT

Ratio: 100.00 A : 5.00 A
 Max burden: 0.20 Ohm
 Accuracy: 3.00 %
 Acc. model: CT-2500
 Acc. serial: 20026010

PT

Ratio: 288.00 V : 120.00 V
 Max burden: 5.00 VA
 Accuracy: 2.00 %
 Acc. model: PT-600
 Acc. serial: 20029250

Measurements

PT

Meas	A	B	C	Unit
U prim	292.0	287.4	290.2	V
U sec	119.4	119.0	119.7	V
PT Ratio	2.446 : 1	2.415 : 1	2.424 : 1	
PT Ratio error	1.89	0.62	1.06	%
PT Delta Angle	359.8	-0.022	0.151	°

CT

Meas	A	B	C	Unit
I prim	58.47	61.17	60.11	A
I sec	3.005	3.010	3.012	A
CT Ratio	97.29 : 5.00	101.6 : 5.00	99.78 : 5.00	
CT Ratio error	-2.720	1.600	-0.210	%
CT Delta Angle	-0.161	-0.637	0.034	°

User-defined questions

Tech name	Carlos
-----------	--------